

(19.11) The radiometric sensitivities for discovering ^{59}Fe , ^{131}I , and ^{90}Sr are 75, 25, and 0.74 kBq m⁻³ of water. In the Würgassen plant the total permitted aqueous annual release is 17 Ci β-emitters. Assume an activity ratio in the cooling water of 100:10:1 for the three nuclides above and that none of these activities exceed 1% of the permissible release. How many times must a liquid sample taken each day be concentrated to meet these requirements?

$$Bq := \text{sec}^{-1} \quad Ci := 3.7 \cdot 10^{10} \cdot Bq$$

$$P_{hrlevel} := 17 \cdot Ci \cdot \text{yr}^{-1}$$

$$V_{cooling} := 95000 \cdot \text{m}^3 \cdot \text{hr}^{-1}$$

$$P_{real} := P_{hrlevel} \cdot \frac{1}{100}$$

1% of permitted release level for any nuclide; ^{59}Fe will be the limiting case for activity concentrations.

$$S_{59Fe} := \frac{P_{real}}{V_{cooling}}$$

$$S_{59Fe} = 7.553 \cdot \text{m}^{-3} \cdot Bq \quad R_{59Fe} := 75 \cdot 10^3 \cdot Bq \cdot \text{m}^{-3}$$

$$S_{131I} := \frac{P_{real}}{V_{cooling}} \cdot \frac{1}{10}$$

$$S_{131I} = 0.755 \cdot \text{m}^{-3} \cdot Bq \quad R_{131I} := 25 \cdot 10^3 \cdot Bq \cdot \text{m}^{-3}$$

$$S_{90Sr} := \frac{P_{real}}{V_{cooling}} \cdot \frac{1}{100}$$

$$S_{90Sr} = 0.076 \cdot \text{m}^{-3} \cdot Bq \quad R_{90Sr} := 0.74 \cdot 10^3 \cdot Bq \cdot \text{m}^{-3}$$

$$Conc_{59Fe} := \frac{R_{59Fe}}{S_{59Fe}}$$

$$Conc_{59Fe} = 9.929 \cdot 10^3$$

$$Conc_{131I} := \frac{R_{131I}}{S_{131I}}$$

$$Conc_{131I} = 3.31 \cdot 10^4$$

$$Conc_{90Sr} := \frac{R_{90Sr}}{S_{90Sr}}$$

$$Conc_{90Sr} = 9.797 \cdot 10^3$$

Answer: ^{131}I is the critical nuclide, requires 33100 times; *i.e.* about 33000 times